



NEW ENERGY SOURCES REQUIRE UNIQUE FIRE PROTECTION

4 Ways to Optimize Off-Gas Detection
Design in Li-Ion Battery Racks

Honeywell

Lithium-ion (Li-ion) battery energy storage systems (BESSs) are the unsung heroes of the green transition. From containerized, modular stationary solutions to large built environments, Li-ion battery racks make large-scale deployment of renewable energy possible, anytime, anywhere. But this transformative technology comes with unique fire risks, which demand special attention. This is where off-gas detection comes in. Here are four key considerations to optimize the design of an off-gas detection system for Li-ion battery racks.

1. KNOW YOUR BATTERY RACK

Knowing a BESS inside out is key to designing an optimized off-gas detection system.

There are three main types of Li-ion BESSs:

- **Containerized** – battery racks within shipping containers
- **Modular** – battery racks within small pods
- **Built Environment** – battery racks within a room or a building

Battery racks come in two main categories: open frame or cabinet. Specific rack designs, however, will often have different requirements depending on the manufacturer. A trained fire engineering consultant will help you design an off-gas monitoring system that matches your battery rack brand and model.

2. DON'T FALL FOR FALSE POSITIVES

Identifying any locations where external air may enter the BESS is vital. These can include personnel entry points and HVAC supply points.

Keeping on top of these locations is key to avoiding false positives from your off-gas monitoring system, which may be triggered by external contaminants.

Reference sensors, located near outside air entry points throughout the battery system, will enable you to eliminate false positives.

Sensors should always be positioned in a way that allows fresh air to pass over the sensing face. Once again, seek the advice of a trained consultant to find the best locations for your off-gas sensors.

3. GO WITH THE FLOW

Rack-level air flow is another key design consideration. Battery modules are often equipped with cooling fans that, combined with the BESS HVAC, generate air movement through the battery rack.

The rack-level air flow coincides with the so-called hot and cold aisles of the HVAC system. Cool air is introduced in the cold aisle passing through the battery modules/rack while hot air is expelled into the hot aisle and exhausted via the HVAC system.

Remember: off-gas monitoring sensors should always be installed in the hot aisles while reference sensors should be located in the cold aisles.

4. BURST WITH SAFETY

Sealed battery modules may be equipped with pressure burst discs. These devices are designed to release off gas that may be generated during abuse of the battery cells.

The monitoring sensors should always be installed on the same side of the rack where the burst discs reside. The sensors will then be optimally placed to detect off gas and prevent thermal runaway.

We have now introduced you to some of the most important considerations when designing an off-gas monitoring system for battery racks. We always recommend that you partner with a trusted and trained fire engineering supplier to ensure the system design is optimized for your specific BESS.

For more information

hwll.co/advanced-detection

Honeywell Fire Solutions

12 Clintonville Road
Northford, CT 06472

HW-FY-4waysLi-IonBatteryRack | 02/22
© 2022 Honeywell International Inc.

THE
FUTURE
IS
WHAT
WE
MAKE IT

Honeywell